WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35377
Permit No.
Basin 162

NOTICE OF INTENT NO. 8036

1. OWNER Philip Richards
MAILING ADDRESS
ADDRESS AT WELL LOCATION Wilson Rd.

2. LOCATION NE ¼ SW ¼ Sec. 15 T. 20s N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 35-351-14 (Parcel No.) Bolling Green Acres Parcel 1 Lot 15 Blk1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	18'	18'
calichie		18'	20'	2'
clay		20'	40'	20'
calichie		40'	45'	5'
gravel		45'	50'	5'
clay gravel		50'	60'	10'
calichied	WB	60'	70'	10'
clay		70'	84'	14'
calichie	WB	84'	90'	6'
clay		90'	110'	20'
calichie	WB	110'	113'	3'
clay		113'	126'	13'
calichie	WB	126'	129'	3'
clay		129'	136'	7'
calichie	Wb	136'	139'	3'
clay		139'	140'	1'

RECEIVED
JUL 17 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 7-3, 19 91
Date completed 7-10, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0' Feet	140' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation factory sawcut
Size perforation 1/8 x 3
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1462
Signed Thomas Dem (By driller performing actual drilling on site or contractor)
Date 7-15-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627