WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35405
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8887

1. OWNER Mike Diaz
MAILING ADDRESS c/o Stratus Construction
113 W. New York, Suite B, Las Vegas, NV 89102

ADDRESS AT WELL LOCATION
Sunrise Mtn. on Copper

2. LOCATION SE ¼ NE ¼ Sec. 35 T. 20 S R. 62 E. Clark County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & clay		0	140	140
Cemented gravel		140	160	20
Soft dk. brown clay		160	180	20
Brown clay		180	200	20
Cemented graavel		200	220	20
Hard limestone		220	280	60
Gravel & clay mixed		280	300	20
Brown sandy clay		300	320	20
Dk. gray clay & shale		320	340	20
Gray clay & gravel		340	360	20
Voollcanic roke		360	380	20
Volcanic rock & clay		380	420	40
Cemented gravel		420	440	20
Limestone		440	475	35

RECEIVED
JUN 17 1991
Div. of Water Resources
Branch Office: Las Vegas, NV

Date started June 4, 1991
Date completed June 12, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 475 feet
inches
inches
Casing record
Weight per foot Thickness .188

Diameter	From	To
8 inches	+1 feet	474 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 475 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 3"
From 415 feet to 474 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 289 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 W. Harmon, Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date June 13, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627