


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.300



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Jan Phil Jensen ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SE 1/4 Sec 2 T 21s N/S R 53 E Nye County
 PERMIT NO. N/A 44-072-32 Manko Sub. Lot 62
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	38'	38'
caliche		38'	40'	2'
clay		40'	64'	24'
caliche	<u>W.B.</u>	64'	68'	4'
clay		68'	78'	10'
caliche	<u>W.B.</u>	78'	79'	1'
clay		79'	81'	2'
caliche	<u>W.B.</u>	81'	84'	3'
clay		84'	115'	31'
caliche	<u>W.B.</u>	115'	120'	5'
clay		120'	138'	18'
caliche	<u>W.B.</u>	138'	140'	2'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 140' Feet 0' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From 140 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, Nv. 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas D...
 By driller performing actual drilling on site or contractor
 Date 7-1-91

Date started 6-24 1991
 Date completed 6-28 1991

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 JUL 09 1991
 Div. of Water Resources
 Branch Office - Las Vegas, NV

