



WELL DRILLER'S REPORT

Please complete this form in its entirety

in Book

NOTICE OF INTENT NO. 8004

PRINT OR TYPE ONLY

1. OWNER Gene & Penny Banse ADDRESS AT WELL LOCATION Rhonda
 MAILING ADDRESS _____

2. LOCATION NW 1/4 NE 1/4 Sec 11 T 21 N/S R 53 E Nye County
 PERMIT NO. N/A 44-292-02 Joycelyn Est Lot 16 Blk 6
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	2'	2'
calichie		2'	4'	2'
clay		4'	18'	14'
calichie		18'	20'	2'
clay		20'	40'	20'
calichie		40'	42'	2'
clay		42'	57'	15'
calichie		57'	59'	2'
clay		59'	65'	6'
calichie	WB	65'	68'	3'
clay		68'	80'	12'
calichie	WB	80'	83'	3'
clay		83'	110'	27'
calichie	WB	110'	112'	2'
clay		112'	118'	6'
calichie	WB	118'	124'	6'
clay		124'	134'	10'
calichie	WB	134'	140'	6'

RECEIVED

JUN 17 1991

Div. of Water Resources
 Branch Office Las Vegas, NV

Date started 5-28 1991
 Date completed 6-3 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 140' feet
 _____ inches
 _____ inches
 Casing record 140' x 8.5/8
 Weight per foot 16.94 Thickness 1.88

Diameter	From	To
<u>8.5/8</u> inches	<u>0'</u> feet	<u>140'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140' feet to 50' feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3"
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 54 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling
Contractor
 Address HCR 78 Box 80358 Pahrump, NV, 89041
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Banse
By driller performing actual drilling on site or contractor
 Date 6-11-91

