

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

35420
 OFFICE USE ONLY
 Log No. 35420
 Permit No. 162
 Basin. 162
 NOTICE OF INTENT No. 8028

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Lynn Alsop ADDRESS AT WELL LOCATION Rhonda St.
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NE 1/4 Sec. 11 T. 21s. N/S R. 53 E. Nye County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 44-292-06 Joycelyn Est. Lot 20 B 6
 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	15'	15'
caliche		15'	20'	5'
clay		20'	30'	10'
caliche		30'	31'	1'
clay		31'	47'	16'
caliche		47'	49'	2'
clay		49'	60'	11'
caliche		60'	61'	1'
clay		61'	73'	12'
caliche	WB	73'	76'	3'
clay		76'	89'	13'
caliche	WB	89'	92'	3'
clay		92'	113'	21'
caliche	WB	113'	114'	1'
clay		114'	120'	6'
caliche	WB	120'	123'	3'
clay		123'	132'	9'
caliche	WB	132'	134'	2'
clay		134'	140'	6'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/2 Inches To 140' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From 140 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Div. of Water Resources
 Branch Office - Las Vegas, NV
 Date started 6-24 1991
 Date completed 6-28 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358
Pahrump, Nv. 89041 Contractor
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-1-91