

Log No. 35424

Permit No. _____

Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 8046

1. OWNER Earl Weinstein ADDRESS AT WELL LOCATION Vickie Ann
 MAILING ADDRESS _____

2. LOCATION NE 1/4 SE 1/4 Sec. 11 T. 21s N/S R. 53 E Nye County
 PERMIT NO. N/A Issued by Water Resources 44-311-08 Parcel No. Joycelyn Est. Lot 7 Blk. 8 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	10'	10
caliche		10'	11'	1
clay		11'	21'	10
caliche		21'	26'	5
clay		26'	35'	9
caliche		35'	37'	2
clay		37'	62'	25
caliche	WB	62'	64'	2
clay		64'	84'	20
caliche	WB	84'	86'	2
clay		86'	90'	4
caliche	WB	90'	92'	2
clay		92'	115'	23
caliche	WB	115'	117'	2
clay		117'	131'	14
caliche	Wb	131'	138'	7
clay		138'	140'	2

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/2 Inches _____ Feet 140' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0'</u>	<u>140'</u>

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 140' feet to 50' feet

RECEIVED
 JUL 29 1991
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 7-12 1991
 Date completed 7-20 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, Nv. 89041

Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 7-22-91

