

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 35427
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 8017

1. OWNER Denise Geiser ADDRESS AT WELL LOCATION Bridger
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NW 1/4 Sec. 14 T. 21s. N/S R. 53 E Nye County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 44-734-05 Mesa Oeste Lot 13 Blk. 7 Unit 3 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	5'	5'
caliche		5'	7'	2'
clay		7'	10'	3'
caliche		10'	13'	3'
clay		13'	24'	11'
caliche		24'	29'	5'
clay		29'	44'	15'
caliche		44'	46'	2'
clay		46'	56'	10'
caliche	WB	56'	62'	6'
clay		62'	75'	13'
caliche	WB	75'	78'	3'
clay		78'	83'	5'
caliche	WB	83'	88'	5'
clay		88'	96'	8'
caliche	WB	96'	106'	10'
clay		106'	115'	9'
caliche	WB	115'	117'	2'
clay		117'	125'	8'
caliche	WB	125'	126'	1'
clay		126'	136'	10'
caliche	WB	136'	138'	2'
clay		138'	140'	2'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/4 Inches 0' Feet 140' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 78 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6-24 1991
 Date completed 6-28 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 JUL 29 1991
 Div. of Water Resources
 Branch Office Las Vegas, NV

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, Nv. 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1602
 Division of Water Resources, the on-site driller. 1573
 Signed Thomas D...
 By driller performing actual drilling on site or contractor
 Date 7-22-91