WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35475
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8882 & 8885 (2nd sent in error)

1. OWNER Bob Verchota
MAILING ADDRESS 1605 Bryn Mawr
Las Vegas, NV 89102

ADDRESS AT WELL LOCATION West Windmill Rd.

2. LOCATION NW¼ SE ¼ NE ¼ Sec. 17 T. 22 S R. 60 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Caliche		0	20	20
Conglomerate		20	100	80
Boulders		100	220	120
Clay & small boulders		220	340	120
Bigger booulders		340	360	20
Red rock & lime boulders		360	400	40
Limestone,cem. gravels		400	440	40
Red rock & lime boulders		440	520	80
Red rock		520	620	100
Hard limestone		620	760	140
Gravel & lime boullders		760	795	35

RECEIVED
JUN 17 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started May 22, 1991
Date completed June 10, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 795 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness 3/16"

Diameter	From	To
8 inches	+1 feet	795 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 56 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 56 feet to 795 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 3"
From 732 feet to 795 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 660 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSOON DRILLING CO., INC. (Contractor)
Address 4185 W. Harmon Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1750
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date June 13, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627