


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340



Log No. 35480
 Permit No. _____
 Basin _____

NOTICE OF INTENT NO. 7008

1. OWNER JELLY LEONARD ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 9165 S. TELLER

2. LOCATION SW 1/4 NW 1/4 Sec. 22 T. 22 N/S R. 60 E CLARK County _____
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary
 Other _____

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thick-ness
SAND-ROCKS-		0	12	12
CMT GRAVEL		12	98	86
LIME STONE		98	105	7
CMT GRAVEL		105	141	36
LIME STONE		141	460	319
RED SAND STONE		460	485	25
LIME STONE		485	519	34
RED SAND STONE		519	560	41
LOST CIRCULATION		560	700	140

8. WELL CONSTRUCTION
 Total Depth 700 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 700 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.9</u>	<u>.188</u>	<u>+2</u>	<u>700</u>
<u>40' of P.C.G. From 660 to 700</u>				

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 Feet to 700 Feet

RECEIVED

MAY 20 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 499 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LEE R. THOMAS Contractor
 Address 5965 N. MAVERICK Contractor
LAS VEGAS NEV.

Date started 5-2- 19 91
 Date completed 5-16- 19 91

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Nevada contractor's license number issued by the State Contractor's Board 10831
 Nevada contractor's driller's number issued by the Division of Water Resources 623
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 623
 Signed Lee R. Thomas
 By driller performing actual drilling on site or contractor
 Date 5-16-91