

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Riverside Resorts, Inc C/O The Planning Group ADDRESS AT WELL LOCATION Riverside Resort  
 MAILING ADDRESS P.O. Box 69 Bullhead City, AZ 86430 1650 Casino Dr. Laughlin, NV 89029  
 2. LOCATION 1/4 NW 1/4 Sec 13 T 32 N R 60 E Clark County  
 PERMIT NO. MO-2095  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravelly Sand</u>		<u>0'</u>	<u>2'</u>	<u>2'</u>
<u>Silty Sand</u>		<u>2'</u>	<u>5'</u>	<u>3'</u>
<u>Sandy Clay</u>		<u>5'</u>	<u>7'</u>	<u>2'</u>
<u>Silty Sand</u>		<u>7'</u>	<u>20'</u>	<u>13'</u>
<u>Gravelly Sand-Cobbles x</u>		<u>20'</u>	<u>30'</u>	

8. WELL CONSTRUCTION  
 Diameter 4 inches Total depth 30 feet  
 Casing record PVC - Schedule 40  
 Weight per foot N/A Thickness N/A  
 Diameter From To  
4 inches 0 feet 30 feet  
 Surface seal: Yes  No  Type Cement-Bentonite  
 Depth of seal 12 feet  
 Gravel packed: Yes  No   
 Gravel packed from 12 feet to 30 feet  
 Perforations:  
 Type perforation Machine Slotted - Sch 40 PVC  
 Size perforation 0.020 inch  
 From 15 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 NOV 18 1991  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 10-3, 1991  
 Date completed 10-3, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>N/A</u>		

BAILER TEST  
 G.P.M. N/A Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. N/A Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. N/A Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level = 21 feet below land surface  
 Flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cold °F Quality Poor

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WT Environmental Consultants, Inc Contractor  
 Address 3611 W. Tompkins Ave. Las Vegas, NV 89103 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0033048  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 11-11-91