WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35565
Permit No.
Basin 212

NOTICE OF INTENT NO. 2930

1. OWNER Greg Jasper
MAILING ADDRESS 7920 Maverick
Las Vegas, Nev. 89131

ADDRESS AT WELL LOCATION
7920 Maverick

2. LOCATION NE ¼ NE ¼ Sec. 14 T. 19 N/S R. 60 E. clark County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt & pop corn claichi		0	6	6
calichi		6	9	3
hard brown clay		9	55	46
hard white clay		55	58	3
cemented		58	105	47
silt & gravel & clay		105	165	60
cemented gravel		165	185	20
sand & clay	*	185	211	26
hard brown clay		211	290	29
gravel conglomerate	**	290	305	15
hard brown clay		305	448	143
sand stone		448	455	7
:lay & sand		455	500	45

RECEIVED
NOV 01 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-16, 19 91
Date completed 10-26, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	?	2

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	500 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	500

Perforations:
Type perforation Torch
Size perforation 3/16 x 6" x 4 around
From 340 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 76'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 135 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling Inc. (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Las Vegas, Nev. 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916-0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed Donald L Walk
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627