


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 35578
 Permit No. 55471
 Basin 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2929

1. OWNER Lou Foster ADDRESS AT WELL LOCATION Monte Cristo & La Madre
 MAILING ADDRESS 1581 Equestrian Dr.
Henderson, Nv. 89015

2. LOCATION NE 1/4 SW 1/4 Sec. 34 T 19 N/S R 60 E clark County
 PERMIT NO. 55471 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
silt, pop corn calichi		0	14	14
calichi		14	20	6
silt, gravel congl.		20	26	6
cemented congl.		26	47	21
partially cemented		47	55	8
silt & gravel congl.		55	70	15
brown clay sand & gravel		70	188	118
white clay sand & gravel		188	210	22
brown clay sand & gravel		210	240	30
hard white silty clay & gravel	X	240	270	30
brown clay sand & gravel		270	375	105
sand & gravel		375	400	25
brown clay sand & gravel		400	455	55

8. WELL CONSTRUCTION
 Depth Drilled 455 Feet Depth Cased 455 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	0 Feet 390 Feet
8 Inches	390 Feet 455 Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	455

Perforations:
 Type perforation Torch
 Size perforation 3/16" x 6x4 around

From	feet to	feet
256	376	feet
396	416	feet
436	455	feet
		feet
		feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 80'

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 180 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 8-14 1991
 Date completed 8-20 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	?	1

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling, Inc Contractor
 Address 4847 So. Valley View Blvd. Contractor
Las Vegas, Nevada 89103

Nevada contractor's license number issued by the State Contractor's Board 0018917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661

Signed Fred B Allen
 By driller performing actual drilling on site or contractor
 Date 8-21-91



RECEIVED
 AUG 26 1991
 Div. of Water Resources
 Branch Office - Las Vegas, NV