WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

OFFICE USE ONLY
Log No. 35582
Permit No.
Basin

NOTICE OF INTENT NO. 8245

1. OWNER REBEL OIL COMPANY
MAILING ADDRESS 1900 E. SAHARA AV.
LAS VEGAS, NV 89104

ADDRESS AT WELL LOCATION 5054 N. SLOAN LANE
LAS VEGAS, NV

2. LOCATION NW ¼ SW ¼ Sec 34 T 19 N(S) R 62 E CLARK County

PERMIT NO. MO 2081 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MONITOR
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary
☐ Other

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thickness
SILTY SAND		0	8	8
CALICHE		8	11	3
CLAYEY SILT		11	20	9
SILTY CLAY		20	21	1
SILTY SAND		21	24	3
SILTY CLAY		24	28	4
SILTY GRAVEL		28	32	4
SILTY ~~CLAY~~ SAND		32	35	3
SILTY CLAY		35	38	3
CLAYEY SILT		38	41	3
CALICHE		41	47	6
CLAYEY SILT		47	52	5
SILTY CLAY		52	56	4
CLAYEY SILT		56	59	3
SILTY CLAY		59	61	2
CLAYEY SILT		61	64	3
SILTY CLAY		64	67	3
CLAYEY SILT		67	69	2
SILTY CLAY		69	71	2
CLAYEY SILT		71	76	5
SILTY CLAY		76	83	7
SILTY SAND		83	89	6
SILTY CLAY		89	91	2
CLAYEY SILT		91	93	2
SILTY CLAY		93	98	5
CLAYEY SAND		98	105	7
SILTY CLAY		105	117	12
CLAYEY SILT		117	123	6

Date started AUGUST 20, 19 91
Date completed AUGUST 20, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
SEP 27 1991
Div. of Water Resources
District Office - Las Vegas, NV

8. WELL CONSTRUCTION
Total Depth 123 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	123 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	123

Surface Seal: ☒ Yes ☐ No
Depth of Seal 46
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 46 Feet to 123 Feet

9. WATER LEVEL
Static water level 104 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DON WILSON (Contractor)
Address 4670 S. POLARIS AV. (Contractor)
LAS VEGAS, NV 89103

Nevada contractor's license number issued by the State Contractor's Board

Nevada contractor's driller's number issued by the Division of Water Resources

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1589

Signed [signature]
By driller performing actual drilling on site or contractor

Date

(Rev. 12-90) (O)-627