WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35016
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8292

1. OWNER TFWC-EM
MAILING ADDRESS Nellis AFB, NV 89191-5000
ADDRESS AT WELL LOCATION North of electrical substation

2. LOCATION NE ¼ NE ¼ Sec. 4 T. 20 N/S R. 62 E. Clark County
PERMIT NO. M0-2069 Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ Hollow Stem

6. LITHOLOGIC LOG MW63

Material	Water Strata	From	To	Thickness
Sandy silt (ML)		0	12	12
Silty clay (CL)	1st H2O	12	20	8'
Caliche (Siltstone)		20	21	1'
Silty and sandy clay (CL)	▽ 77'	21	100	79'

RECEIVED
SEP 17 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8/14, 1991
Date completed 8/16, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
—			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth ~~100~~ 101 feet
____ inches
____ inches
Casing record Sched 80 PVC (4")
Weight per foot NA Thickness Sched 80

Diameter	From	To
4 inches	0 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type 3% bent/Portland cement
Depth of seal 62' (bentonite 67'-65') feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 65 feet to 101 feet

Perforations:
Type perforation factory slotted PVC
Size perforation 0.020"
From 70 feet to 100 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ~ 77 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature ~~[illegible]~~ °F Quality cloudy

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name John F Olenski Contractor
Address 8646 Beauxart Cir Sac CA 95828 Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed John F Olenski
By driller performing actual drilling on site or contractor
Date 9/5/91

(Rev. 11 85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627