WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

mBook

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35628
Permit No.
Basin

NOTICE OF INTENT NO. 8060

1. OWNER Reginald Gustin
MAILING ADDRESS
ADDRESS AT WELL LOCATION David

2. LOCATION NE ¼ NW ¼ Sec. 17 T. 20S N/S R. 53 E. NYE County
PERMIT NO. N/A (Issued by Water Resources) | 36-271-01 (Parcel No.) | Calvegas Rancho Lot 1 Unit F (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	6'	6'
Calichie		6'	12'	6'
Clay		12'	31'	19'
Calichie		31'	34'	3'
Clay		34'	54'	20'
Calichie	WB	54'	57'	3'
Clay		57'	72'	15'
Calichie	WB	72'	74'	2'
Clay		74'	79'	5'
Calichie	WB	79'	81'	2'
Clay		81'	92'	11'
Calichie	WB	92'	93'	2'
Clay		93'	101'	8'
Calichie	WB	101'	106'	5'
Clay		106'	115'	9'
Calichie	WB	115'	119'	4'
Clay		119'	124'	5'
Calichie	WB	124'	128'	4'
Clay		128'	137'	9'
Calichie	WB	137'	140'	3'

RECEIVED
OCT 29 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-15, 19 91
Date completed 10-22, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0' Feet	140' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation factory sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed [illegible] (By driller performing actual drilling on site or contractor)
Date 10-24-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627