WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35643
Permit No.
Basin

NOTICE OF INTENT NO. 8323

1. OWNER FRANK MORRISON
MAILING ADDRESS
ADDRESS AT WELL LOCATION HICKORY

2. LOCATION SW ¼ SW ¼ Sec. 28 T. 20 N/S R. 53 E. NVE County
PERMIT NO. (Issued by Water Resources) LOT-10 (Parcel No.) 40-402-10 CALVADA VALLEY (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
CALICHIE		3	7	4
CLAY		7	23	16
CALICHIE		23	29	6
CLAY		29	45	16
CALICHIE		45	48	3
CLAY		48	55	7
CALICHIE		55	59	4
CLAY		59	69	10
CALICHIE	WB	69	72	3
CLAY		72	83	11
CALICHIE	WB	83	86	3
CLAY		86	99	13
CALICHIE	WB	99	104	5
CLAY		104	123	19
CALICHIE	WB	123	126	3
CLAY		126	139	13
CALICHIE	WB	139	142	3
CLAY		142	156	14
CALICHIE	WB	156	160	4

RECEIVED
SEP 20 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-9-, 1991
Date completed 9-16, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
SEP 20 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH BY 3 INC
From 160 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 160 feet to 50 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Dennis Brown (By driller performing actual drilling on site or contractor)
Date 9-17-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627