WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35653
Permit No.
Basin 212

NOTICE OF INTENT NO. 8254

1. OWNER Kristich CORP
MAILING ADDRESS 1126 W. BONANZA
LAS VEGAS NEV

ADDRESS AT WELL LOCATION PENSKE TRUCKING
1126 W. BONANZA
LAS VEGAS NEV

2. LOCATION NW ¼ SE ¼ Sec. 28 T. 20 S/N R. 61 E/W CLARK County
PERMIT NO. MO 2083 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.5'	6"
Silty Sand		0.5	5	4.5'
Silty CLAY		5	9.5	4.5'
CALICHE		9.5	10.5	1.0'
CLAYey Silt		10.5	14	3.5'
Silty clay w/sand		14	19	5.0'
Clayey Silt w/sand		19	24	6.0'
CALICHE		24	25	1.0'

RECEIVED
OCT 01 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-17-91, 19
Date completed 9-17-91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"				

Perforations:
Type perforation FACTORY Slotted
Size perforation 0.020
From 25 feet to 10 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 7'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25 feet to 12 feet

9. WATER LEVEL
Static water level 17' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHAR Leblanc c/o Converse Consultant (Contractor)
Address 4670 S. POLARIS AVE (Contractor)
LAS VEGAS NEV
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589-T1
Signed R. Leblanc (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627