

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

OFFICE USE ONLY

Log No. 35677

Permit No. _____

Basin 11e2

NOTICE OF INTENT NO. 8330

1. OWNER Dennis Albright ADDRESS AT WELL LOCATION Deanna
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec. 11 T. 21 N/S R. 53 E Nye County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 44-321-20 Joycelyn Est. Lot 20 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	5'	5'
calichnie		5'	7'	2'
clay		7'	18'	
calichie		18'	23'	6'
clay		23'	34'	11'
calichie		34'	45'	11'
clay		45'	58'	13'
calichie	TR	58'	63'	5'
clay		63'	76'	13'
calichie	WB	76'	84'	8'
clay		84'	93'	9'
calichie	WB	93'	97'	4'
clay		97'	122'	25'
calichie	WB	122'	127'	5'
clay		127'	136'	9'
calichie	WB	136'	139'	3'
clay		139'	147'	8'
calichie	WB	147'	156'	9'
clay		156'	160'	4'

8. WELL CONSTRUCTION
 Depth Drilled 160' Feet Depth Cased 160' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0' Feet 160' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	160'

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From 160 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 160' feet to 50' feet

RECEIVED

OCT 03 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 9-23, 1991
 Date completed 9-28, 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 54' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Donnie Brown
 By driller performing actual drilling on site or contractor
 Date 9-30-91