

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 35678  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 8331

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Harold Felger ADDRESS AT WELL LOCATION Thousand Air  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SE 1/4 Sec 11 T 21 N/S R 53 E Nye County  
 PERMIT NO. N/A Issued by Water Resources | 44-313-04 Parcel No. | Joycelyn Est. Lot 11 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	8	8
caliche		8	11	3
clay		11	25	14
caliche		25	30	5
clay		30	61	31
caliche	TR	61	66	5
clay		66	72	6
caliche	WB	72	75	3
clay		75	79	4
caliche	WB	79	82	3
clay		82	108	26
caliche	WB	108	111	3
clay		111	123	12
caliche	WB	123	134	11
clay		134	140	6

8. WELL CONSTRUCTION  
 Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/2 Inches 0' Feet 140' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:  
 Type perforation factory sawcut  
 Size perforation 1/8 x 3  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5.0'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 140' feet to 50' feet

RECEIVED  
 OCT 03 1991  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 9-23, 1991  
 Date completed 9-28, 1991

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 5.5' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump, Nv. 89041

Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9-23-91