WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35680
Permit No.
Basin

NOTICE OF INTENT NO. 8310

1. OWNER Paul Moore
MAILING ADDRESS
ADDRESS AT WELL LOCATION Manse Rd.

2. LOCATION NW ¼ NW ¼ Sec. 12 T. 21s N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) 44-511-01 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	10'	10'
calichie		10'	12'	2'
clay		12'	22'	10'
calichie		22'	23'	1'
clay		23'	44'	21'
calichie		44'	48'	4'
clay		48'	59'	11'
calichie	WB	59'	63'	4'
clay		63'	75'	12'
calichie	WB	75'	79'	4'
clay		79'	91'	12'
calichie	WB	91'	93'	2'
clay		93'	109'	16'
calichie	WB	109'	114'	5'
clay		114'	121'	7'
calichoe	WB	121'	124'	3'
clay		124'	136'	12'
calichie	WB	136'	137'	1'
clay		137'	140'	3'

RECEIVED
AUG 28 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8-16, 1991
Date completed 8-20, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0' Feet	140' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation factory sawcut
Size perforation 1/8 x 3
From 140' feet to 120' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 8-26-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627