WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

35712 In Book

OFFICE USE ONLY
Log No. 35712
Permit No.
Basin 220

NOTICE OF INTENT NO. 10430

1. OWNER Clark County School District
MAILING ADDRESS 4828 South Pearl Street
Las Vegas, Nevada 89121

ADDRESS AT WELL LOCATION Moapa High School site, Logandale NV

2. LOCATION NE ¼ SE ¼ Sec. 35 T. 15 N/S R. 67 E. Clark County
PERMIT NO. MO-2088 (Issued by Water Resources) | Parcel No. | Moapa High School (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Hollow stem

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand-yellow brown		0'	3'	3'
Sandy Gravel -grey		3'	12'	9'
Sandy Silt - grey		12'	13'	1'
Sandy Gravel - grey		13'	37'	24'
Sandy Silt - grey		37'	39'	2'
Sandy Gravel - grey		39'	42'	3'
Silty Sand - Lt. brown		42'	45'	3'
Sandy Gravel - grey	51.4'	45'	56'	11'
Silty Clay		56	73'	17'
Bottom at 73'				
Well #2				

RECEIVED
OCT 1 0 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started September 13, 1991
Date completed September 13, 1991

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 73 Feet Depth Cased 73 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches	0 Feet	73 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.67	0.154	0	48
2.375	0.67	0.154	68	73

Perforations:
Type perforation Factory slotted
Size perforation 0.020"
From 48 feet to 68 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 42
Placement Method: ☒ Pumped ~~☒ Poured~~

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 46 feet to 73 feet

9. WATER LEVEL
Static water level 51.4 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LEBLANC (Contractor)
Address (Contractor)

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589T-1

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-26-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627