WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35714
Permit No.
Basin 162

NOTICE OF INTENT NO. 8052

1. OWNER VERNON ARMSTRONG
MAILING ADDRESS
ADDRESS AT WELL LOCATION TECOPA St.

2. LOCATION SE ¼ NE ¼ Sec. 16 T. 19S N/S R. 53 E. NYE County
PERMIT NO. N/A (Issued by Water Resources) | 29-241-07 (Parcel No.) | Country Place II Lot 16 Unit 1 Blk 5 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	15'	15'
Calichie		15'	18'	3'
Clay		18'	57'	39'
Calichie		57'	59'	2'
Clay		59'	105'	46'
Calichie		105'	106'	1'
Clay		106'	113'	7'
Calichie		113'	115'	2'
Clay		115'	155'	40'
Calichie		155'	160'	5'
Clay		160'	175'	15'
Calichie	WB	175'	180'	5'
Clay		180'	186'	6'
Calichie	WB	186'	189'	3'
Clay		189'	197'	8'
Calichie	WB	197'	200'	3'

RECEIVED
OCT 15 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-7, 1991
Date completed 10-11, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0' Feet	200' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	200'

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8 X 3
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 200' feet to 50' feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 10-17-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627