WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35720
Permit No.
Basin

NOTICE OF INTENT NO. 8219

1. OWNER Texaco Refining & Marketing Inc
MAILING ADDRESS 10 Universal City Plaza
University City CA 91608

ADDRESS AT WELL LOCATION Texaco Terminal
5049-B Sloan Lane
North Las Vegas Nevada

2. LOCATION NW ¼ NW ¼ Sec. 34 T. 19 N/S R. 62 E. O Clark County

PERMIT NO. MO 2075 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY silt		0	5	5
		~~5~~	~~6.5~~	1.5
CALICHE		5	6.5	1.5
SANDY silt		6.5	30	23.5
Silty Clay		30	125	95

RECEIVED
SEP 17 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started ....., 19....
Date completed ....., 19....

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 124 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 1/2 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"			0	125

Perforations:
Type perforation Factory Slotted
Size perforation 0.010
From 85 feet to 125 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 75
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 78 feet to 126 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gary Lyons Layne Environmental (Contractor)
Address 9002 South Hardy Drive (Contractor)
Tempe, Az
Nevada contractor's license number issued by the State Contractor's Board .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1682
Signed ..... (By driller performing actual drilling on site or contractor)
Date 8-26-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627