WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35728
Permit No.
Basin

NOTICE OF INTENT NO. 8319

1. OWNER Ron Murphy
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lawrence

2. LOCATION SE ¼ SW ¼ Sec. 23 T 20s N/S R 52 E Nye County
PERMIT NO. N/A (Issued by Water Resources) | 28-464-04 (Parcel No.) | Rancho Vista Est. Lot 33 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	3'	3'
calichie		3'	7'	4'
clay		7'	34'	27'
calichie		34'	36'	2'
clay		36'	62'	26'
calichie		62'	65'	3'
clay		65'	82'	17'
calichie	WB	82'	85'	3'
clay		85'	90'	5'
calichie	WB	90'	98'	8'
clay		98'	115'	17'
caliche	WB	115'	118'	3'
clay		118'	121'	3'
calichie	WB	121'	123'	2'
clay		123'	135'	12'
calichie	WB	135'	140'	5'

Date started ....., 19.....
Date completed ....., 19.....

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
SEP 20 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0' Feet	140' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation factory sawcut
Size perforation 1/8 x 3
From 140' feet to 120' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level ..... feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041

Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed ..... (By driller performing actual drilling on site or contractor)
Date .....

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627