WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 32730
Permit No.
Basin

NOTICE OF INTENT NO. 8336

1. OWNER Mel Bailey
MAILING ADDRESS
ADDRESS AT WELL LOCATION Fritz

2. LOCATION SW ¼ NE ¼ Sec. 24 T. 20s N/S R. 52 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) | 28-782-18 (Parcel No.) | Charleston Park Ranchos Unit 6 Lot 116 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	3'	3'
calichie		3'	5'	2'
clay		5'	19'	14'
calichie		19'	22'	3'
clay		22'	37'	15'
calichie		37'	41'	4'
clay		41'	55'	14'
calichie	WB	55'	58'	3'
clay		58'	66'	8'
calichie	WB	66'	71'	5'
clay		71'	77'	6'
calichie	WB	77'	79'	2'
clay		79'	88'	9'
calichie	WB	88'	91'	3'
clay		91'	106'	15'
calichie	WB	106'	109'	3'
clay		109'	116'	7'
calichie	WB	116'	121'	5'
clay		121'	128'	7'
calichie	WB	128'	136'	8'
clay		136'	140'	4'

RECEIVED
OCT 17 1991
Div. of Water Resources

Date started 9-30, 1991
Date completed 10-4, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0'	140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation factory sawcut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ~~1573~~ 1642
Signed (By driller performing actual drilling on site or contractor)
Date 10-12-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627