WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35735
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8658

1. OWNER Joe ~~Cobe~~ Kohl
MAILING ADDRESS 5124 ALTA DR.
LAS VEGAS, NEV 89107

ADDRESS AT WELL LOCATION
Prospector - Between Woodchip & Barney - Pahrump, Nev

2. LOCATION NE ¼ SW ¼ Sec. 18 T. 20 N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) Parcel No. 89 Subdivision Name CHAS. PK Rancho Unit 5

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Br. Sticky Clay		0	6	6
Hard Br Clay		6	20	14
Soft Br. Clay	x	20	36	16
Sandy Clay	x	36	38	2
Lt Br Clay		38	110	72
Sandy Br Clay	x	110	116	6
Soft Br. Clay		116	140	24
Soft Sandy Br Clay	x	140	150	10
Sticky Dk Br Clay		150	160	10

RECEIVED OCT 28 1991 Div. of Water Resources Branch Office Las Vegas, Nev.

Date started 9/23, 19 91
Date completed 9/30, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 25 feet 1/2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 160 feet
inches
inches
Casing record
Weight per foot Thickness 188

Diameter	From	To
8 inches	0 feet	161 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation Factory Cut
Size perforation 1/8 x 3
From feet to feet
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 41 ft feet below land surface
Flow G.P.M. P.S.I.
Water temperature 68 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name O M Gullard Drilling (Contractor)
Address 6022 S. Eucalyp Ave - LV, NV 89120 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4796
Nevada contractor's driller's number issued by the Division of Water Resources 115
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed O M Gullard
By driller performing actual drilling on site or contractor
Date 10-15-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627