WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35736
Permit No.
Basin

NOTICE OF INTENT NO. 9796

1. OWNER Harry Watson
MAILING ADDRESS
ADDRESS AT WELL LOCATION Starlight Dr.

2. LOCATION SW ¼ NE ¼ Sec. 33 T. 20S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) | 35-484-10 (Parcel No.) | Starlight Oasis Lot 54 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	10'	10'
Calichie		10'	14'	4'
Clay		14'	27'	13'
Calichie		27'	30'	3'
Clay		30'	57'	27'
Calichie		57'	60'	3'
Clay		60'	64'	4'
Calichie		64'	65'	1'
Clay		65'	82'	17'
Calichie	WB	82'	86'	4'
Clay		86'	97'	11'
Calichie	WB	97'	99'	2'
Clay		99'	117'	18'
Calichie	WB	117'	119'	2'
Clay		119'	136'	17'
Calichie	WB	136'	138'	2'
Clay		138'	145'	7'
Calichie	WB	145'	149'	4'
Clay		149'	160'	11'
Calichie	WB	160'	162'	2'
Clay		162'	172'	10'
Calichie	WB	172'	175'	3'
Clay		175'	180'	5'

Date started 9-30, 1991
Date completed 10-4, 1991

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0'	180'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	180'

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8 x 3
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 180' feet to 50' feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 10-17-91

RECEIVED OCT 17 1991 Div. of Water Resources Branch Office - Las Vegas, NV

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627