WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35757
Permit No.
Basin 163

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6148

1. OWNER ROBERT HOLTAM
MAILING ADDRESS 4816 ARAWANA LN
LAS VEGAS NV. 89106

ADDRESS AT WELL LOCATION LAST PLACE NORTH ON KOLO SANDY VALLEY, NV. 89019

2. LOCATION NE ¼ NE ¼ Sec. 36 T. 24 N/S R. 56 E. CLARK County

PERMIT NO. (Issued by Water Resources) | Parcel No. 586-260-022 | Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	3	3
CLAY		3	39	36
CALICHE		39	43	4
CONS CLAY		43	70	27
ROCK & CLAY	WTR	70	73	3
CALICHE	WTR	73	75	2
WHITE CLAY		75	114	39
BROWN SANDY CLAY		114	128	14
WHITE CLAY		128	136	12
CALICHE	WTR	136	138	2
BRN CLAY		138	140	2

RECEIVED OCT 11 1991 Division of Water Resources Las Vegas, NV

Date started SEPT 15, 1991
Date completed OCT 1, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	25	2FT	2

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 14 inches Total depth 140 feet
inches
inches

Casing record STEEL
Weight per foot 18 LBS Thickness 1/8"

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation FLAME CUT
Size perforation 5/16 x 4" 4 ROWS @ 16" CTRS
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 68 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 70 °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name RCBB INC. (Contractor)
Address 1701 W CASTLE, LAS VEGAS, NV. 89102 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 1352

Nevada contractor's driller's number issued by the Division of Water Resources 1352

Nevada driller's license number issued by the Division of Water Resources, the on-site driller

Signed Robert Spurlock (By driller performing actual drilling on site or contractor)
Date Oct 6-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627