WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35777
Permit No.
Basin 212

NOTICE OF INTENT NO. 5230

1. OWNER Molly Van Pulliam/Sav-Tym
MAILING ADDRESS 18351 Beach Blvd. Ste. D
Huntington Beach, CA. 92648

ADDRESS AT WELL LOCATION
Blue Diamond & Shellbourne

2. LOCATION NE ¼ NW ¼ Sec. 18 T. 22 N/S R. 61 E. Clark County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt & boulders		0	6	6
silty sand & boulders		6	26	20
silt sand & gravel				
conglomerate		26	60	34
cemented conglomerate		60	176	116
gravel conglomerate		176	180	4
cemented conglomerate		180	188	8
clay sand & gravel		188	272	84
partially cemented		272	325	53
clay sand & gravel	X	325	360	35
gravel conglomerate		360	422	62
limestone grey		422	433	11
partially cemented		433	450	17
cemented		450	500	50

RECEIVED
SEP 25 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-4, 19 91
Date completed 9-12, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	?	2

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	500 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	500

Perforations:
Type perforation Torch
Size perforation 3/16x6x4 around
From 330 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 270 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling, Inc. (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Las Vegas, Nev. 89103
Nevada contractor's license number issued by the State Contractor's Board 0018917-0018916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed Donald L Wall (By driller performing actual drilling on site or contractor)
Date 9-18-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627