

OFFICE USE ONLY  
 Log No. 35798  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

I

16189

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 16189

PRINT OR TYPE ONLY

1. OWNER JOB'S PEAK CONSTRUCTION ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3170 Vista Grande 263 Apple Creek Lane  
Carson City, NV 89703 Gardnerville, NV 89410

2. LOCATION SW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 3 T. 12 S. R. 19 E. Douglas County  
 PERMIT NO. 19-390-15 Candle Rock  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	4	4
DG, multi-colored, soft to medium hard		4	122	118
Granodiorite, highly fractured with water	xx	122	140	18
TD is 140 feet				

91 FEB 21 P 2:02  
 STATE ENGINEERS OFFICE

Date started Feb 1 1991 - 1990  
 Date completed Feb 4 1991 - 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed drill mud from well and gravel packed well.	Blew well for 2 hours to clean and develop.	Blew 20 gpm from	115 feet

BAILER TEST

G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours

8. WELL CONSTRUCTION  
 Diameter 11 1/2 to 100 inches Total depth 140 feet  
9 1/2 inches  
 Casing record Steel 6 5/8"  
 Weight per foot 13.03 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>4.2</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete  
 Depth of seal 100 feet  
 Gravel packed: Yes  No   
 Gravel packed from 100 feet to 140 feet

Perforations:  
 Type perforation Factory Mill Slotted  
 Size perforation 3" x 3/32"  
 From 115 feet to 135 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 53 feet below land surface  
 Flow 20-22 G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A & H PUMP CO. Contractor  
 Address Carson City, NV 89701 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 23295  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1624  
 Signed Joey Brub By driller performing actual drilling on site or contractor  
 Date Feb 6, 1991