WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35807
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. [illegible]

1. OWNER Time Oil Co. ADDRESS AT WELL LOCATION 1535 Hwy 395
MAILING ADDRESS 2737 W. Commodore Way Minden Nev
Seattle Wa 98199

2. LOCATION NE ¼ NW ¼ Sec. 32 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. [illegible] Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE MW3
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☑ Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Brown Sand and gravel		0	8'	8'
Light Brown gravelly Coarse Sand		8'	15'	7'

Date started 2/8, 1991
Date completed 2/8, 1991

7. N/A WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. N/A Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 15 feet
..... inches
..... inches
Casing record PVC
Weight per foot N/A Thickness Sch 40

Diameter	From	To
2 inches	0 feet	15 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Bentonite & Grout
Depth of seal 4 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 4 feet to 15 feet

Perforations:
Type perforation Slotted
Size perforation 010
From 5 feet to 15 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 9' feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature 64 °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [illegible] Contractor
Address 1635 Delford Rd Reno Nev 89[illegible] Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1023
Signed [illegible] By driller performing actual drilling on site or contractor
Date 3/24/91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

#35807

LOG OF: B-5 (MW-3)

DATE: 1-31-91

ELEV:



Depth	PID No.	PID (ppm)	HAL Test (ppm)	Sample No.	Blows per 6 in.	Samples	Graphic Log	Description/Soil Classification
								2 inches AC.
								FILL: Brown sand and gravel (GM), loose, slightly moist, slight petro odor.
5				5-5.5	4			
				5-6	5			
					11			
				5-7.5	8			
	181	653?		5-8	13			
					10			Light brown gravelly coarse sand (SP), medium dense, saturated.
10								
	182	11.1		5-12	23			
					26			
					39			
15								BOH @ 15.5'
20								
25								
30								
35								

Porter Geotechnical, Ltd.

Proj No: 9101.1 Total Depth: 15.5

Water Level: 9.07 (2-7) Driller: Andresen

A & H Liquor

Plate 7