WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35868
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16189

1. OWNER PAINTER CONSTRUCTION COMPANY
MAILING ADDRESS P.O. Box 37, Genoa, Nevada 89411
ADDRESS AT WELL LOCATION 1530 Wildflower Court, Gardnerville, NV 89410

2. LOCATION SE ¼ NE ¼ Sec 35 T 13 N/S R 20 E Douglas County
PERMIT NO. (Issued by Water Resources) 23-470-02 (Parcel No.) Blk F lot 4, Wildflower Ridge (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Sand mixed with gravel		3		75
Clay seam, sandy, brown coloration		75		93
Gravel, hard		93		98
Clay, tight, brown		98		165
Clays mixed with gravels		165		178
Gravels, clean	xxx	178		200
TD at 200 ft				

Date started Feb 5, 1991
Date completed Feb 7, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clean water to remove drill mud and gravel pack. Developed well with air for 4 hours to clean. Blowing 20 plus gpm from 160 ft.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11½ to 100 inches; 9½ inches; inches — Total depth 200 feet
Casing record Steel 6 5/8"
Weight per foot 13.03 Thickness .188

Diameter	From	To
6 5/8 inches	2 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 100 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 200 feet

Perforations:
Type perforation Factory Mill Slotted
Size perforation 3" x 3/32"
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 80 feet below land surface
Flow 20 plus G.P.M. P.S.I.
Water temperature cold °F Quality godd

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joey Betts (By driller performing actual drilling on site or contractor)
Date Feb 7, 1991

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627