WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 35815
Permit No.
Basin 9-108

NOTICE OF INTENT NO. 23576

1. OWNER O-N Ranch
MAILING ADDRESS P.O. Box 1576 Dayton Nev. 89432
ADDRESS AT WELL LOCATION 205 N Bybee Lane Yerington Nev 89447

2. LOCATION NE ¼ NW ¼ Sec. 22 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 14-321-06 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil Sandy		0	3	3
Coarse Sand		3	12	9
Brown Clay		12	18	6
Coarse Sand		18	23	5
Brown Clay		23	28	5
Brown Clay + Sand		28	34	6
Brown Clay + Coarse Sand to Gravel 1 to 2' thick		34	126	92
Coarse Sand + Gravel	X	126	135	9
Coarse Sand + Clay		135	150	15
Hard Brown Clay		150	158	8
Brown Clay + Coarse Sand		158	170	12
Coarse Sand	X	170	175	5
Brown Clay + Coarse Sand		175	180	5
Bluish Clay + Sand		180	185	5
Coarse Sand + Gravel	X	185	195	10
Brown Clay + Coarse Sand		195	205	10
Blue Clay		205	212	7
Brown Clay + Sand		212	215	3
Brown Clay, Sand, Gravel		215	218	3
Blue Clay		218	226	8
Coarse Sand + Gravel Small Rock	XX	226	258	32

Date started 2-11, 19 91
Date completed 2-15, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIROPEV	100 +		4 HRS
FROM 63'			

BAILER TEST
G.P.M. 22 Draw down 2' feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 5/8" inches Total depth 258 feet
inches
inches
Casing record 188
Weight per foot Thickness 188

Diameter	From	To
6 5/8 inches	+1 feet	258 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 258 feet

Perforations:
Type perforation Factory Sawed-Mill
Size perforation 3/32 x 3" x 6 Rows
From 238 feet to 258 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 16.3 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N Bybee Lane (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Larry Ogden (By driller performing actual drilling on site or contractor)
Date 2-20-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627