

WELL DRILLER'S REPORT
Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15439

1. OWNER ALAZZI RANCHES ADDRESS AT WELL LOCATION O D GABLE
MAILING ADDRESS 51 ALAZZI LANE YERINGTON
YERINGTON, NV 89447

2. LOCATION SW 1/4 NW 1/4 Sec. 32 T. 14 N/S R. 26 E. LYON County
PERMIT NO. C-5868 Permit # 18712 N/A Subdivision Name

3. TYPE OF WORK REDRILL
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1
HARD CLAY		1	3	2
FINE SAND		3	9	6
COARSE SAND		9	13	4
BROWN SANDY CLAY		13	16	3
COARSE SAND W/S SMALL GRAVEL		16	37	21
BROWN CLAY		37	43	6
SAND & GRAVEL		43	58	15
BROWN CLAY		58	64	6
SAND & GRAVEL	X	64	73	14
BROWN CLAY		73	93	4
SAND & GRAVEL	X	93	93	11
BROWN CLAY		93	100	7
SAND & GRAVEL	X	100	110	8
BROWN CLAY		110	122	4
SAND & GRAVEL	X	122	135	13
CLAY W/S SAND STRINGERS		135	141	6
SAND & GRAVEL W/S CLAY STRINGERS		141	150	9
CLAY		150	155	5
SAND & GRAVEL	X	155	162	7
CLAY		162	167	5
SAND & GRAVEL	X	167	177	10
CLAY		177	182	5
SAND & GRAVEL	X	182	215	33
CLAY W/S SAND STRINGERS		215	221	6
SAND & GRAVEL	X	221	248	27

8. WELL CONSTRUCTION

Diameter _____ inches Total depth 400 feet
36 inches 0 to 50
24 inches 50 to 400

Casing record 15'
 Weight per foot _____ Thickness .257

Diameter	From	To
30" CONDUCTOR	+1	50
16" BLANK	+1	100
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Surface seal: Yes No Type GROUT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 0 feet to 400 feet

Perforations:
 Type perforation ***SEE BELOW***
 Size perforation 1/8 X 3
 From 100 feet to 140 SR MILD ST feet
 From 140 feet to 240 DR MILD ST feet
 From 240 feet to 340 LOUVERED feet
 From 340 feet to 400 SCREEN feet

Date started FEBRUARY 20 continued on page 2
 Date completed FEBRUARY 22

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	3500	82	8

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 10.10 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.5 °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Address P.O. Box 592 Wmca., NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 215234
 Nevada contractor's driller's number issued by the Division of Water Resources 1154
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 795
 Signed [Signature]
 Date 3-8-91

WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No.
 Permit No.
 Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15430

1. OWNER ATAZZI RANCHES ADDRESS AT WELL LOCATION O. D. GABLE
 MAILING ADDRESS 51 ATAZZI LANE YERINGTON
YERINGTON, NV 89447
 2. LOCATION SW 1/4 NW 1/4 Sec. 32 T. 14 N/S R. 26 E LYON County
 PERMIT NO. 3858 N/A Parcel No. N/A Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CONTINUED FROM PAGE ONE				
CLAY W/S SAND STRINGERS		248	265	17
SAND & GRAVEL	X	265	273	8
CLAY W/S SAND STRINGERS		273	284	11
SAND & GRAVEL	X	284	301	17
CLAY		301	314	13
SAND & GRAVEL	X	314	327	13
CLAY W/S SAND STRINGERS		327	331	4
SAND & GRAVEL	X	331	395	64
CLAY		395	400	5

8. WELL CONSTRUCTION

Diameter.....inches Total depth.....feet
inches
inches

Casing record.....
 Weight per foot.....Thickness.....

Diameter	From	To
.....inchesfeetfeet

Surface seal: Yes No Type.....
 Depth of seal.....feet
 Gravel packed: Yes No
 Gravel packed from.....feet to.....feet

Perforations:
 Type perforation.....
 Size perforation.....
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Date started....., 19.....
 Date completed....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level.....feet below land surface
 Flow.....G.P.M.....P.S.I.
 Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Address P.O. Box 592 Wmca., NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 215234
 Nevada contractor's driller's number issued by the Division of Water Resources 1154
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 795
 Signed [Signature]
 Date 3-8-91

BAILER TEST

G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours
 G.P.M. Draw down.....feethours