

OFFICE USE ONLY
 Log No. 35817
 Permit No. _____
 Basin 8-104

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1619

1. OWNER IRIS FRANCOUR ADDRESS AT WELL LOCATION Lot 7, Blk 131
 MAILING ADDRESS 25 Canyon Drive 25 Canyon Drive
Carson City, NV 89703 Carson City, NV 89703
 2. LOCATION NW 1/4 SW 1/4 Sec. 13 T. 15 Q/S R. 19 E. Carson City County
 PERMIT NO. 07-131-07 Kings Canyon Estates Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden, (loose fill)		0	15	15
Solid granite boulders with thin clay lenses		15	145	130
Sandy clay seam		145	150	5
Boulders and granite carrying water from 187 to 220	xxx	150	220	70
TD is 220 feet				

8. WELL CONSTRUCTION

Diameter 10 3/4 inches Total depth 220 feet
9 1/2 inches
 inches

Casing record Steel 6 5/8"
 Weight per foot 13.03 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>4.2</u> feet	<u>220</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes No Type Concrete
 Depth of seal 100 feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 220 feet

Perforations:
 Type perforation Factory Mill Slotted
 Size perforation 3" x 3/32"
 From 200 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 126 feet below land surface
 Flow 20 plus G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started Feb 11 1991
 Date completed Feb 22 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed drill mud from well and gravel-packed well. Developed well with 250-450 air for 3 hours until clean. NOTE: although static level is quite high, pumping level at 20 gpm is 200 feet			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO.
CARSON CITY, NV 89701
 Address _____ Contractor
 Nevada contractor's license number issued by the State Contractor's Board 23295
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1674
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date Feb 23, 1991