pg. 1 of 2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35839
Permit No.
Basin 87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17263

1. OWNER NV Medical Liability Ins. Co./Al Ashley
MAILING ADDRESS P.O. Box 7456, Reno, NV 89510
ADDRESS AT WELL LOCATION Mobil Station, SE Corner of 4th & Lake Streets, Reno, NV

2. LOCATION SE ¼ NE ¼ Sec. 11 T 19N N/S R 19 E Washoe County
PERMIT NO. M/O #367 B-2 MW-2 (Issued by Water Resources) Parcel No. Close to downtown area (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE Monitoring X: Domestic ☐ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphaltic concrete,				
Brown clayey sand		0	4	4
Brown clayey sand, med.				
dence, moist		4	10	6
Light brown silty sand		10	24	14
Gray brown poorly				
graded gravel with				
silt and sand		24	29.9	5.9

NOTE: THIS LOG TO REPLACE INCOMPLETE LOG 3-19-91

Date started 2-14-91, 19
Date completed 2-14-91, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 9 5/16 inches Total depth 29.9 feet
inches
inches
Casing record 29 ft. PVC installed.
Weight per foot Thickness sch 40

Diameter	From	To
2" inches	0 feet	29 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Bentonite 2 ft. &
Depth of seal Cement grout 16 ft feet
Gravel packed: Yes ☒ No ☐ Sand #3 Monterey
Gravel packed from 18 feet to 29.9 feet

Perforations:
Type perforation factory sawed slot
Size perforation 0.01"
From 19 feet to 29 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 24.1 2-15-90 feet below land surface
Flow N/A G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 29, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

LOG OF BORING B-2

Equipment Tubex Pneumatic Drill Rig

Elevation _____ Date 2/14/91

Depth (ft)	Sample	Description
0		2-1/4" ASPHALTIC CONCRETE (AC)
		BROWN CLAYEY SAND (SC); loose to medium dense, moist, small pieces of concrete, old nails, small chunks of AC and bricks (FILL)
5		BROWN CLAYEY SAND (SC); medium dense, moist
		BROWN LEAN CLAY (CL); stiff, moist to wet
10		LIGHT BROWN SILTY SAND (SM); medium dense, moist, very fine sand
15		
20		Color change to gray-brown, wet
25		GRAY BROWN POORLY GRADED GRAVEL WITH SILT AND SAND (GP-GM); dense, saturated
30		Boring terminated at 29.9'. Free groundwater measured at 24.1' on 2-15-91. Converted to monitoring well MW-2 on 2-14-91.
35		
40		