WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 3-6617
Permit No.
Basin 101

**PRINT OR TYPE ONLY**

NOTICE OF INTENT NO. 6549

1. OWNER FRANCIS VIERRA
MAILING ADDRESS 5521 Casey Road
Fallon, Nevada 89406

ADDRESS AT WELL LOCATION
5525 Casey Road
Fallon, Nevada

2. LOCATION SE ¼ NW ¼ Sec. 32 T. 19 N/S R. 28 E Churchill County
PERMIT NO. N/A (Issued by Water Resources) 8-651-16 (Parcel No.) Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil | | 0 | 3 | 3 |
| Fine sand | | 3 | 18 | 15 |
| Coarse sand | | 18 | 24 | 6 |
| Fine sand | | 24 | 30 | 6 |
| Coarse sand | x | 30 | 34 | 4 |
| Brown clay | | 34 | 35 | 1 |

'91 FEB 19 A11:02
STATE ENGINEER

Date started February 12, 1991
Date completed February 12, 1991

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 35 feet
..... inches
..... inches
Casing record ASTM-A-53-A
Weight per foot 12.92 Thickness .188

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 35 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 25 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 25 feet to 35 feet

Perforations:
Type perforation Mill cut
Size perforation 1/8"
From 30 feet to 35 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 5 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P. O. Box 1265, Fallon, Nv. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada contractor's driller's number issued by the Division of Water Resources 1454
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696
Signed [illegible] (By driller performing actual drilling on site or contractor)
Date 2-14-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627