WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No.
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14678

1. OWNER Sierra Vista Properties, Inc Mark Andelin
MAILING ADDRESS 50 Freeport Blvd. Suite 19, Sparks, Nv 89431
ADDRESS AT WELL LOCATION 7950 Pyramid Lake Hwy # 445, Parcel 1 of Land Map 125

2. LOCATION NW ¼ SW ¼ Sec. 2 T. 20 N/S R. 20 E. Washoe County
PERMIT NO. — (Issued by Water Resources) 83-120-48 (Parcel No.) Spanish Springs (Subdivision Name)

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ] Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	8	8
Brown clay multi-colored sands		8	86	78
Fine multi-colored sands & little clay		86	101	15
Gravel		101	107	6
Compact clay		107	112	5
Clay & sands		112	129	17
Mostly fine multi-colored sands		129	197	68
Brown clay		197	203	6
T.D. 203				
20 ft blank on bottom open ended. Seated 1 ft in brown clay				
T.D. 203 ft				

Date started 2/14/91, 19
Date completed 2/15/91, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 203 feet
inches
inches
Casing record 6 5/8 inch
Weight per foot 12.92 Thickness .188

Diameter	From	To
6 5/8 inches	+ 2 feet	204 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type neat cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 203 feet

Perforations:
Type perforation Screen - Roscoe-Moss
Size perforation .030
From 173 feet to 183 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 10 feet below land surface
Flow 20 G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L Sparks 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site~~ driller 1132
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 2/19/91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627