WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35893
Permit No.
Basin 76

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17009

1. OWNER Ray LaVoie
MAILING ADDRESS PO Box 1019
Fernley

ADDRESS AT WELL LOCATION
940 Mesa Dr.
FERNLEY, NV. 89408

2. LOCATION NE ¼ SE ¼ Sec. 10 T 20 N/S R. 24 E Lyon ~~Storey~~ County
PERMIT NO. (Issued by Water Resources) Parcel No. 20-141-01 Subdivision Name ~~Fernley~~ Wagner Heights

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	22	22
BROWN SANDY CLAY		22	61	39
SANDY CLAY W/cobbles	—	61	70	9
SAND CLAY W/small	—	70	110	40
STREAKS OF SAND				
COARSE SAND AND		110	135	25
GRAVEL				

Date started Feb 20, 1991
Date completed Feb 21, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
NA	NA	NA	NA

~~BAILER~~ TEST AIR LIFT

G.P.M. 20 Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 135 feet
____ inches
____ inches
Casing record 13 6
Weight per foot ____ Thickness 188

Diameter	From	To
6 5/8 inches	0 feet	135 feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet
____ inches	____ feet	____ feet

Surface seal: Yes ☒ No ☐ Type Cement grout
Depth of seal 51 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 51 feet to ____ feet

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From 95 feet to 135 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 70' feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality Clear at time of test

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling (Contractor)
Address PO Box 1345 Dayton NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4739 A
Nevada contractor's driller's number issued by the Division of Water Resources 249
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 590
Signed Clyde L Enloe (By driller performing actual drilling on site or contractor)
Date March 20, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

'91 APR 10 A7:03

RECEIVED
STATE ENGINEERS OFFICE