WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35883
Permit No.
Basin

I

PRINT OR TYPE ONLY

NOTICE OF INTENT No. 16542

1. OWNER ADOBE HEIGHTS INC.
MAILING ADDRESS P.O. Box 430
Elko, NV 89801

ADDRESS AT WELL LOCATION from north 5th street-2 miles north of Elko city limits

2. LOCATION SE ¼ NE ¼ Sec. 1 T. 34 N/S R. 54 E. Elko County
PERMIT NO. Waiver #W-327 (Issued by Water Resources) | Parcel No. | Adobe Heights (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	20	20
Sandstone-Lt brown		20	70	50
Gravel & sand		70	80	10
Gravel & clay	120	80	135	55
Siltstone-olive		135	170	35
Shale-dk grey & brown		170	200	3
Shale-greenish grey		200	210	10
Shale-dk grey	220	210	240	30
Shale-dk grey & brown		240	270	30
Shale-greenish grey		270	300	30
Shale-grey	380	300	600	300
	450			

'91 FEB 25 A11:45
RECEIVED
STATE ENGINEERS OFFICE

Date started February 17, 1991
Date completed February 21, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow test	100		

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 600 feet
inches
inches
Casing record
Weight per foot Thickness .188

Diameter	From	To
6 5/8 inches	+1 feet	600 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 100 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 600 feet

Perforations:
Type perforation MILL SLOT
Size perforation 1/8 x 2½
From 212 feet to 233 feet
From 374 feet to 395 feet
From 456 feet to 477 feet
From 498 feet to 519 feet
From 539 feet to 560 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 Elko, NV 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada contractor's driller's number issued by the Division of Water Resources 1166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Darel Hirsh
By driller performing actual drilling on site or contractor
Date 2-22-1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627