

OFFICE USE ONLY
 Log No. 35896
 Permit No. _____
 Basin 61

FW-14
 PRINT OR TYPE ONLY

WELL DRILLER'S REPORT
 Please complete this form in its entirety

NOTICE OF INTENT No. 16365

1. OWNER FARRICK GOLD SIRIKE MINE ADDRESS AT WELL LOCATION FARRICK MINE
 MAILING ADDRESS PO BOX 29
ELKO, NV. 89801

2. LOCATION SE SW 19 T. 36 N. R. 50 E. EUREKA County
 PERMIT NO. 55424-T Parcel No. N/A Subdivision Name N/A

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAY ROCK		0	140	140
GRAY ROCK, SOME CLAY		140	150	10
GRAY ROCK		150	260	110
GRAY CLAY		260	270	10
GRAY ROCK		270	330	50
GRAY CLAY		330	380	50
GRAY ROCK	X	380	400	20
GRAY ROCK & CLAY		400	535	135
GRAY ROCK	X	535	600	65
GRAY CLAY, SOME ROCK		600	700	100
GRAY ROCK		700	910	210

'91 MAR -1 AD 51
STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION

Diameter 35 inches Total depth 30 feet
22 inches 910'
 inches

Casing record 24" 95 LB/FT .375"
 Weight per foot 16" 63 LB/FT Thickness .375"

Diameter	From	To
<u>24</u> inches	<u>0</u> feet	<u>30</u> feet
<u>16</u> inches	<u>0</u> feet	<u>905</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 905 feet

Perforations:
 Type perforation LOWER
 Size perforation 3" X 1/16"

From	To
<u>395</u> feet	<u>895</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Date started JANUARY 5 19 91
 Date completed FEBRUARY 3 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 163 feet below land surface
 Flow N/A G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor
 Address 2286 WEST 1500 SOUTH, SALT LAKE CITY, UT. 84104 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada contractor's driller's number issued by the Division of Water Resources 1365
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1639

Signed Pat Jensen
 By driller performing actual drilling on site or contractor
 Date FEBRUARY 25, 1991