

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. T158X

1. OWNER Larry Miller
 MAILING ADDRESS P.O. Box 2221
Gardnerville, Nev. 89410
 ADDRESS AT WELL LOCATION 838 Cayuse Dr.
Gardnerville, Nev. 89410

2. LOCATION SE 1/4 SE 1/4 Sec. 13 T. 12 N N/S R. 20 E Douglas County
 PERMIT NO. 29-441-19 Ruhenstroth Ranchos Subdivision Name
 Issued by Water Resources Parcel No.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, Sandy		0	18	18
Clay, Sticky		18	35	17
Gravel		35	97	62
Clay		97	112	15
Gravel		112	150	38
Clay, Sandy		150	156	6
** Gravel	X	156	218	62
Clay, Gravel streaks		218	236	18
Gravel		236	268	32
Clay, Sticky		268	283	15
Gravel	X	283	310	27
** Insufficient water at this depth to develop, or for domestic use.				

APR 30 AM 10:38 '91

8. WELL CONSTRUCTION
 Diameter 12 1/4" 0-50' inches Total depth 310' feet
8 3/4" 50'-280' inches
6 1/8" 280'-310' inches
 Casing record 6 5/8" 0-280'--5" 280-310'
 Weight per foot _____ Thickness 0.188

Diameter	From	To
<u>6 5/8" inches</u>	<u>0 feet</u>	<u>280 feet</u>
<u>5 inches</u>	<u>280 feet</u>	<u>310 feet</u>
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Concrete Grout
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 280 feet

Perforations:
 Type perforation Factory Slotted
 Size perforation 3/32" X 3"
 From 200 feet to 220 feet
 From 240 feet to 260 feet
 From 270 feet to 310 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started March 7, 1991, 1991
 Date completed March 15, 1991, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Airlift</u>	<u>22GPM</u>		

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 152 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Not Known

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Pre-Cambrian Drilling Co., Inc. Contractor
 Address 794 Foothill Rd. Gardnerville, Nv. Contractor
 Nevada contractor's license number 0030267 issued by the State Contractor's Board
 Nevada contractor's driller's number 1652 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
 Signed _____ By driller performing actual drilling on site or contractor
 Date March 23, 1991