

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 35926
Permit No. _____
Basin 97-108

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5435

PRINT OR TYPE ONLY

1. OWNER GENE MENRSINI ADDRESS AT WELL LOCATION MACKENzie LANE
MAILING ADDRESS P.O. BOX 289 YERINGTON
YERINGTON, NV. 89447
2. LOCATION NE 1/4 NE 1/4 Sec. 11 T 12 N/S R. 25 E LYON County
PERMIT NO. 28067 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. TYPE OF WORK REDRILL
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation
Municipal Industrial
5. TYPE WELL
Cable Rotary
Other Test
Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	8	8
GRAVEL W/S BOULDERS & SOME CLAY		8	30	22
CLAY IMBEDDED IN ROCK		30	50	20
SAND & BOULDERS	X	50	70	20
BROWN CLAY W/SAND IMBEDDED-SOME BOULDERS		70	140	70
SAND & GRAVEL W/S CLAY	Y	140	150	10
SOFT CLAY W/S SAND & BOULDERS		150	189	39
BOULDERS W/S SAND & GRAVEL	Y	189	197	8
CLAY W/S SAND & BOULDERS		197	200	3
SAND, GRAVEL & BOULDERS W/S CLAY	Y	200	210	10
SAND & GRAVEL W/S CLAY	Y	210	310	100
BOULDERS IN BROWN CLAY W/S SAND		310	332	22
CLAY W/SMALL AMT OF SAND IMBEDDED		332	341	9
SAND, GRAVEL & 10% CLAY	Y	341	343	2
CLAY W/SAND IMBEDDED		343	354	11
SAND & BOULDERS, SOME CLAY IMBEDDED	Y	354	380	26
BROWN CLAY W/S GRAVEL		380	400	20

8. WELL CONSTRUCTION
Diameter.....inches Total depth 400.....feet
.....36 inches from 0 to 50'
.....24 inches from 50' to 400'
Casing record 1 to 50' 30" conductor
Weight per foot 50' to 400' 16" casing Thickness .250
Diameter From To
16" BLANK.....inches.....2 feet.....60 feet
.....inches.....feet.....feet
.....inches.....feet.....feet
.....inches.....feet.....feet
.....inches.....feet.....feet
Surface seal: Yes No Type GROUT
Depth of seal.....50 feet
Gravel packed: Yes No
Gravel packed from.....50 feet to.....400 feet
Perforations:
Type perforation MILL SLOT & LOUVERED
Size perforation 1/8 X 3
From.....60 feet to.....110 FE LOUVERE feet
From.....110 feet to.....160 SP LOUVERE feet
From.....160 feet to.....200 DR MILL SL feet
From.....200 feet to.....220 SR MILL SL feet
From.....220 feet to.....240 DR MILL SL feet

Date started MARCH 1, 1991
Date completed MARCH 5, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>1000</u>	<u>146.2</u>	<u>8</u>

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
Static water level.....35 feet below land surface
Flow.....G.P.M.....P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Husboldt Drilling & Pump Co., Inc Contractor
Address P.O. Box 592 Wmca., NV 89445 Contractor
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada contractor's driller's number issued by the Division of Water Resources 115 4
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 795
Signed [Signature] By driller performing actual drilling on site or contractor
Date _____

