

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.370 and NAC 534.340

NOTICE OF INTENT NO 16313

1. OWNER Greg Gamble ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1650 Stephanie 2814 Esaw
Minden, NV 89423

2. LOCATION S2 1/4 S2 1/4 Sec 26 T 14 N/S R. 20 E Douglas County
 PERMIT NO. SW SW 21-240-36 Johnson LU Subdivision Name

Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary
 Other _____

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>15</u>	
<u>Broken Rock, sand</u>		<u>15</u>	<u>68</u>	
<u>Small Gravel</u>		<u>68</u>	<u>98</u>	
<u>Clay + Sand</u>		<u>98</u>	<u>200</u>	
<u>Gray clay + rock stringers</u>		<u>200</u>	<u>230</u>	
<u>sand, course</u>		<u>230</u>	<u>238</u>	
<u>clay</u>		<u>238</u>	<u>260</u>	
<u>Course sand + Gravel</u>		<u>260</u>	<u>280</u>	

'91 MAY 20 9:39
 RECEIVED
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION
 Total Depth 280 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 289 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>Perf</u>	<u>1.188</u>	<u>0</u>	<u>280</u>

260' - 280' Perf
factory mill slot

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 Feet to 289 Feet

Date started 3/20, 1991
 Date completed 3/25, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>7.25</u>	<u>N/A</u>	<u>4 HRS</u>

9. WATER LEVEL
 Static water level 165 feet below land surface
 Artesian flow _____ G.P.M. 7.25 P.S.I.
 Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kawchack Drilling Inc Contractor
 Address Rt # 3 2668 Fuller Contractor
Minden, NV 89423

Nevada contractor's license number issued by the State Contractor's Board 021268
 Nevada contractor's driller's number issued by the Division of Water Resources 1380
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1534

Signed Marvin Hack
 By driller performing actual drilling on site or contractor
 Date 4/2/91