

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 16093

PRINT OR TYPE ONLY

1. OWNER Rocky Nelson ADDRESS AT WELL LOCATION 2970 Lake Shore Drive, New Washoe City  
 MAILING ADDRESS 2970 Lake Shore Drive  
 2. LOCATION SW 1/4 SW 1/4 Sec 31 T 17N N/S R 20 E Washoe County  
 PERMIT NO. 50-403-03 New Washoe City Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	10	10
Brown Clay		10	12	2
Brown Sand		12	21	9
Gray Sand AND CLAY		21	106	85
GRAVEL		117	120	14

pumpin's  
 Level 100FT

8. WELL CONSTRUCTION  
 Diameter hole 12 1/4 inches Total depth 120 feet  
 Casing record \_\_\_\_\_  
 Weight per foot 13 Thickness 1.88  
 Diameter From To  
6 5/8 inches 0 feet 120 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type NEAT CEMENT  
 Depth of seal 100 feet  
 Gravel packed: Yes  No   
 Gravel packed from 100 feet to 120 feet  
 Perforations:  
 Type perforation MILL STOT  
 Size perforation 2 1/2 x 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 105 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Flow 20 G.P.M. P.S.I.  
 Water temperature Cold ° F. Quality unknown

Date started 3-19, 1991  
 Date completed 3-21, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CASTLE DRILLING CO. Contractor  
 Address 12000 S. VIRGINIA BLVD, 89511 Contractor  
 Nevada contractor's license number 27767  
 Nevada contractor's drillers number 1600  
 Nevada driller's license number 1287 Actual Driller  
 Signed Andy Little Contractor  
 Date 3-22-91

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours