

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 17256

1. OWNER CHARLES & DOROTHY WILTSIE ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 605 Calle De la Plata
Sparks, NV 89436

2. LOCATION NE 1/4 NE 1/4 Sec 19 T. 21N N/S R. 21 E Washoe County
 PERMIT NO. 076-690-41 Spanish Springs Valley
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Cable <input type="checkbox"/>
Recondition <input type="checkbox"/>	Irrigation <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
Deepen <input checked="" type="checkbox"/>	Industrial <input type="checkbox"/>	Other <input type="checkbox"/>
Other <input type="checkbox"/>	Test <input type="checkbox"/>	Air <input type="checkbox"/>
	Stock <input type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>WELL DEEPENING:</u>				
Well at 476 Yield 15 GPM				
Fill		476	480	4
Gray granite		480	540	60
Soft zone (NO WATER)		540	542	2
Gray granite		542	650	8
Cave in over night to 618 ft				
No more H2O encountered.				
<i>Deepening of log # 10041</i>				
<i>9/78</i>				

8. WELL CONSTRUCTION

Diameter 6 1/8 inches Total depth 650 feet
 _____ inches caved in to 618
 _____ inches

Casing record 185 ft steel liner installed.
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>5 1/2</u> inches	<u>433</u> feet	<u>618</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type N/A
 Depth of seal _____ feet
 Gravel packed: Yes No drop liner
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Factory sawed slot
 Size perforation 3/32x3x5 around
 From 453 feet to 473 feet
 From 513 feet to 533 feet
 From 593 feet to 613 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 3-6-91, 19____
 Date completed 3-7-91, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 305 feet below land surface
 Flow 15 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
Contractor
 Address P.O. Box 12370, Reno, NV 89510
Contractor
 Nevada contractor's license number _____
 issued by the State Contractor's Board 22549
 Nevada contractor's driller's number 908
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date March 13, 1991