WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36026
Permit No.
Basin 49

PRINT OR TYPE ONLY

1. OWNER Gil STATES
MAILING ADDRESS 1232 Hyland Dr ELKO
ADDRESS AT WELL LOCATION Corner of 5th & Arlington
NOTICE OF INTENT NO. 15315

2. LOCATION NE ¼ NW ¼ Sec. 1 T. 35 N/S R. 56 E/W ELKO County
Lot 1 - Blk 22
Meadow Valley Ranchos Subdivision Name
PERMIT NO. Issued by Water Resources
36/08075 Parcel No.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	4	4
SAND		4	15	11
CLAY Light Cream color		15	25	10
SAND	water	25	38	13
CLAY		38	70	32
Lime STONE		70	105	35
SAND	water	105	111	6
SAND STONE		111	128	17
SAND Gravel	water	128	140	12

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 140 feet
inches
inches
Casing record STEEL
Weight per foot Thickness .250

Diameter	From	To
6 inches	+ 2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 55
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 140 feet

Perforations:
Type perforation 5/0 + 5
Size perforation 3/16 - 3"
From 120' feet to 140' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 16 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

Date started 3-12, 19 91
Date completed 3-18, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow Test	40-45	50'	2

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Co Contractor
Address P.O. Box 525 ELKO NV 89801 Contractor
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] By driller performing actual drilling on site or contractor
Date 3-24-91

(Rev. 11-85)

USE ADDITIONAL SHEETS IF NECESSARY

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No.
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15319

1. OWNER Gilbert ALANIS
MAILING ADDRESS
ADDRESS AT WELL LOCATION Block 24 Fifth Street Lot No 3

2. LOCATION NE ¼ NE ¼ Sec. 6 T. 34 N/S R. 56 E. Elko County
PERMIT NO. (Issued by Water Resources) UNIT 1 Lot 24 (Parcel No.) Meadow Valley Ranchos (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	15	15
Gravel		15	18	3
Clay		18	159	141
Sand Stone		159	162	3
Clay		162	175	13
Sand Stone	water	175	194	19
Clay		194	200	6

Date started 9-10 1990
Date completed 9-20 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 175-200 Draw down 40 feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 200 feet
inches
inches
Casing record STEEL
Weight per foot Thickness .188

Diameter	From	To
6 inches	21 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 60 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 60 feet to 200 feet

Perforations:
Type perforation Slots
Size perforation 3/16 3"
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 2 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AA Drilling Co (Contractor)
Address 255 West Rice St (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 20684
Nevada contractor's driller's number issued by the Division of Water Resources 904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-24-90