

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 15311

PRINT OR TYPE ONLY

1. OWNER Ted Prescott ADDRESS AT WELL LOCATION CORNER OF Eight ST and Taft Ave  
 MAILING ADDRESS 627 N HAYLAND

2. LOCATION NW 1/4 NW 1/4 Sec 36 T 36 N/S R 56 E ELKO County  
 PERMIT NO. 65-1 Parcel No. Meadow Valley Ranches Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	10	10
Gravel		10	19	9
light Blond CLAY		19	41	22
SAND		41	43	2
Light TAN CLAY		43	204	161
SAND & CLAY		204	210	6
CLAY Brown		210	214	4
<del>CLAY Cream color</del>		<del>214</del>	<del>226</del>	
SAND	water	214	218	4
CLAY Cream color		218	236	18
SAND	water	236	241	5
CLAY Brown		241	248	7
SAND		248	260	2

MAY 27 1991

8. WELL CONSTRUCTION

Diameter 6" inches Total depth 260 feet

Casing record STEEL

Weight per foot \_\_\_\_\_ Thickness 158

Diameter	From	To
<u>6"</u> inches	<u>7.15"</u> feet	<u>260</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement

Depth of seal 55 feet

Gravel packed: Yes  No

Gravel packed from 55 feet to 260 feet

Perforations:  
 Type perforation slots  
 Size perforation 3/16 - 3"  
 From 210 feet to 250 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 2-28, 1991  
 Date completed 3-12, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Company  
 BAILER TEST

G.P.M. 60-70 Draw down 120 feet 3 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 96' feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor  
 Address PO Box 525 Elko NV 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 31904

Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Sheldon J. Taylor  
 By driller performing actual drilling on site or contractor

Date 3-24-91