

Log No. 36060
Permit No. Waiver #MO-2015

WELL DRILLER'S REPORT

Basin 64A

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 4133

1. OWNER Whiskey Pete's ADDRESS AT WELL LOCATION 1/15 & Stateline
MAILING ADDRESS P.O. Box 95997 Well #MW-7
Las Vegas, Nevada 89193-5997

2. LOCATION SE 1/4 SE 1/4 Sec. 32 T 26S N/S R. 59 E Clark County
PERMIT NO. Waiver #MO-2015 Unk. Parcel No. Unk. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock Other

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt with sand (fine-med) and some cobbles		0	111	
Boulders/rock chips of quartz & granit, very little silt.		111	150	
Silt increases with sand (fine-Med.) & some cobbles.		150	180	
Cobbles increase with silt & sand (fine) some white clay.		180	250	

91 APR -8 A9 15
STATE ENGINEER'S OFFICE
RECEIVED
APR 15 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION

Diameter 4" inches Total depth 250' feet

Casing record ASTMA53-B inches
Weight per foot _____ Thickness 3/16"

Diameter	From	To
<u>4"</u> inches	<u>0</u> feet	<u>100</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Neat Cement
Depth of seal 50' feet
Gravel packed: Yes No
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation Mill Slot
Size perforation .030
From 100 feet to 250 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Date started 3-7- 1991
Date completed 3-8- 1991

9. WATER LEVEL
Static water level 113 feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F. Quality _____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>N/A</u>			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Howard Pump, Inc.
Address P.O. Box 1249, Barstow, CA 92312-1249
Nevada contractor's license number issued by the State Contractor's Board 27389
Nevada contractor's driller's number issued by the Division of Water Resources 436
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1644
Signed Anthony Villanueva
By driller performing actual drilling on site of contractor
Date 3-8-91

BAILER TEST
G.P.M. 2 Draw down 23 feet 3 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours