

OFFICE USE ONLY  
 Log No. 36071  
 Permit No. 44298  
 Basin: 137-B

**WELL DRILLER'S REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 14595

1. OWNER Copper Range Co.  
Round Mountain Gold Corp.  
 MAILING ADDRESS P.O. Box 480  
Round Mountain, NV 89095  
 ADDRESS AT WELL LOCATION Mine site  
(in open pit)

2. LOCATION NE 1/4 NW 1/4 Sec 30 T. 10 N. R. 44 E. Nye County  
 PERMIT NO. 44298 Issued by Water Resources Parcel No. #351 Patented Claim Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other P/A

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
welded Teffs		0	340	
	Fractures			
Plug and Abandon Notice				
Reason: Dry				
Application used:				
R/H w/ csg Ripper to				
T.D. Rip csg 2 cuts				
per foot, 1/2 x 3' slots				
from T.D. to 60'				
R/H w/ D.P. to				
T.D., pump from bottom to				
top 14' w/ neat cement.				
PCH and add from top				
lyd neat cement.				
cement mixture 5-7 lb/cu ft 1 cut.				
15.1 PPG				
Abandon date <u>6-17-91</u>				

8. WELL CONSTRUCTION

Diameter 17 1/2 inches Total depth 340 feet  
15 inches  
 inches

Casing record:  
 Weight per foot 28.04 Thickness 0.50

Diameter	From	To
<u>16</u> inches	<u>0</u> feet	<u>18</u> feet
<u>10</u> inches	<u>+ 3</u> feet	<u>340</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes  No  Type Neat cement  
 Depth of seal 60 feet  
 Gravel packed: Yes  No   
 Gravel packed from  feet to  feet

Perforations:  
 Type perforation Milled slot  
 Size perforation 1/8 x 3

From	To
<u>60</u> feet to	<u>340</u> feet
feet to	feet
feet to	feet
feet to	feet
feet to	feet

Date started Construction date 10-1, 1990  
 Date completed 10-4, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>N/A</u>		

BAILER TEST Air Lift

G.P.M.	Draw down	feet	hours

9. WATER LEVEL (At construction)

Static water level 4 feet below land surface  
 Flow 200 G.P.M. N/A P.S.I.  
 Water temperature 60 °F Quality MINERAL

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Weyer Drilling Co Contractor  
 Address 4662 Maynard Sparks NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 24521  
 Nevada contractor's driller's number issued by the Division of Water Resources 1374  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
 Signed Leslie Wright  
 By driller performing actual drilling on site or contractor  
 Date 7-15-91